



मदन भंडारी स्थानीय विज्ञान प्रतिष्ठान

Madan Bhandari Academy of Health Sciences

(मदन भंडारी स्थानीय विज्ञान प्रतिष्ठान ऐन, २०७६ अन्तर्गत स्थापित)



पत्र संख्या :-

चलानी नं. :- Notice No:- 44

Date: 6th January 2026

Regarding Clarification

1. Specific Experience Requirement (Clause 2.4.2)

The bidding document specifies that the bidder must have experience as a *prime supplier in at least two (2) contracts within the last three (3) years.*

a) Number of Contracts

Requiring experience in two (2) separate contracts may be restrictive, as successful completion of one similar contract of comparable nature, scope, and complexity can demonstrate a bidder's technical and managerial capability.

OK, Hospital is ready to amend the specific experience requirement clause of 2 contracts and change it to 1 contract.

b) Experience Timeframe Limiting experience to the last three (3) years may exclude capable firms with relevant experience over a longer period. We kindly request consideration of a broader and more inclusive criterion (up to 10 years) to promote fair competition.

The Specific Experience is required to be within 3 years, which seems a valid time frame rather than such long time frame like 10 years. So, no changes.

2. Technical Specifications and Scope Definition

Subject Q1: Who's Scope? Civil Foundation for STP Customer or client's scope?

Supplier's scope will be limited to installation from pre-treatment tank to discharge of the final result of decontaminated liquid.

Q2: Other Queries

Capacity of STP	Required capacity is 10,000 Litre per hour.	Listed Capacity = 10,000 i.e. 240,000 Liters per ls Is this the required capacity?
-----------------	---	---

Dimension of Civil Platform is also not provided. Around 20-30 ft. length, 10 ft wide.

LPH day?

Collection Pipeline from sources like Hemodialysis, operating rooms, ICU, dental department, laundry, kitchen and even toilets etc.,	Customer or client's scope?	Size of pipeline is also not provided.
--	-----------------------------	--

Collection upto pre-treatment tank is not in the scope of supplier

Bhim Sagar Guragain
Registrar